



NOTES:

1. A RIGID LINER SHALL BE USED INSIDE OF TUBING AT THE COMPRESSION FITTINGS ON 1", 1-1/2" AND 2" SERVICE LINES.
2. ALL FITTINGS SHALL BE COMPATIBLE WITH SERVICE SIZE.
3. SERVICE LINE INSTALLATION AT EXISTING OR NEW MONOLITHIC CURB, GUTTER & SIDEWALK SHALL HAVE THE UTILITY BOX LOCATED BEHIND THE SIDEWALK.
4. SERVICE LINE INSTALLATION AT A LOCATION WITH NO CURB, GUTTER & SIDEWALK SHALL HAVE THE UTILITY BOX LOCATED BEHIND THE FUTURE SIDEWALK.