


2" PRESSURIZED IRRIGATION AIR VALVE



4" PRESSURIZED IRRIGATION AIR VALVE

**NOTES:**

1. MANHOLE COVER TO BE A SOLID LID CONTAINING ONE PICK HOLE. SEE SPECIFICATION DIVISION 5 FOR COVER LABEL. D&L 1180 OR APPROVED EQUIVALENT MANHOLE FRAME AND LID THAT READS "PRESSURIZED IRRIGATION" AS APPROPRIATE
2. LID SHALL BE OF ECCENTRIC DESIGN AND MEET H20 LIVE LOADING.
3. IF POSSIBLE MOVE VALVE OUT OF LINE OF ACCESS.
4. CONCRETE FOR COLLARS SHALL UTILIZE FIBER MESH.