



- NOTES:
1. MANHOLE COVER TO BE A SOLID LID CONTAINING ONE PICK HOLE. SEE SPECIFICATION DIVISION 5 FOR COVER LABEL. D&L 1180 OR APPROVED EQUIVALENT MANHOLE FRAME AND LID THAT READS "WATER"
 2. LID SHALL BE OF ECCENTRIC DESIGN AND MEET H20 LIVE LOADING. NO FLAT RING AND COVERS WILL BE ALLOWED UNLESS APPROVED BY THE CITY ENGINEER OR HIS REPRESENTATIVE.
 3. UNDER WET CONDITIONS INSTALL A DRAIN ABOVE THE WATER TABLE AND BELOW THE VALVE.
 4. IF POSSIBLE MOVE VALVE OUT OF LINE OF ACCESS.
 5. CONCRETE FOR COLLARS SHALL UTILIZE FIBER MESH.