

## **Addendum #01**

Bid #2020-006

Baxter Substation Battery, Rack, Charger Specification

The D/C Output Breaker on the Chargers need to be 25 Amp or 35 Amp, not 30 Amps.

**Quote Both.**

The A/C Input Breaker Ratings need to be to 10 KAIC, not 25 KAIC.