

Addendum #02

Bid #2020-006

Baxter Substation Battery, Rack, Charger Specification

Clarification on Addendum #01

1. The D/C Output **ratings** on the chargers need to be changed to 25 Amp and 35 Amp, as this seems to be the industry standard. So, the manufacture reps should be asked to bid both output ratings and we can determine which one is the best buy for our application, depending on price and functionality.
2. The Chargers A/C Input Breaker Ratings need to be changed to 10 KAIC as this seems to be industry standard after closer investigation. We can simply increase the panel Breaker feeding the Charger inside the control building when installation is done.